

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES

WATER DISTRICT NO. 37 & 37 M

P.O. Box T
Shoshone, Idaho 83352
(208) 886-2451



LEE R. PETERSON
Watermaster

April 16, 2003

Gary Osborne
1776 E 1625 S
Gooding, Idaho

COPY

Dear Gary,

I received your message you left on the answering machine this morning. Becca Braun the new Deputy and myself went to the sight of your pumps, that pump your decreed water. I also tried to call you and left a message on your answering machine. 35-P3 has a Micrometer meter installed and is very satisfactory. However 35-P1 does not have a meter or a measuring device. The structure in front the pump is not a measuring device it is an old control gate used to turn the water into the pump.

The cabinet on this pump is presently locked. Let Becca or I know when you have the meter installed and we will come and remove the lock.

Enclosed is a copy of IDWR's letter in regards to 35-P1 and 35-P3. If you have any questions feel free to give me a call.

Sincerely,

A handwritten signature in black ink, appearing to read "Lee R. Peterson", is written over a horizontal line.

Lee R. Peterson
Watermaster

CC: Allen Merritt, IDWR
Bob Esterbrook, Chairman American Falls Reservoir Dist.

RECEIVED

APR 17 2003

Department of Water Resources
Southern Region